



CITY OF LODI

COUNCIL COMMUNICATION

AGENDA TITLE: Plans and Specifications and Advertisement for Bids for the Blakely Park Balance Tank and Filtration System Replacement

MEETING DATE: November 15, 1995

PREPARED BY: Public Works Director


RECOMMENDED ACTION: That the City Council approve the plans and specifications for the above project and authorize advertising for bids.

BACKGROUND INFORMATION: Last summer, the balance tank for the north pool at Blakely Park collapsed and the pool has been out of service for the past three months. The balance tank is used to keep the water level in the pool at a constant elevation and is needed to prevent the use of excessive amounts of water. This project will abandon the existing balance tank and install a new one.

Included in this project is the replacement of the filter system for the south pool at Blakely Park. The existing filter system is forty years old and the steel tanks have corroded to the point where the Parks Division is constantly repairing leaks and blowouts in the walls of the tanks. The existing filters will be replaced with a smaller, more efficient system.

The filtration system replacement project was approved in the 1995 Capital Improvement Budget and the Parks and Recreation Department has funds available to install a new balance tank. A recommendation on the appropriation of funds will be included in the Council Communication for the award of this project.

FUNDING:	Originally Budgeted:	1995
	Budgeted Fund:	Capital Improvement Fund
	Total Project Estimate:	\$50,000
	Planned Bid Opening Date:	December 20, 1995



Jack L. Ronko
Public Works Director

Prepared by Wesley K. Fujitani, Senior Civil Engineer

JLR/WKF/lm

cc: Purchasing Officer
Parks and Recreation Director

APPROVED: _____



H. DIXON FLYNN
City Manager



recycled paper