



**CITY OF LODI
COUNCIL COMMUNICATION**


IM

AGENDA TITLE: Report on Repairs to a Turbine Pump at the White Slough Water Pollution Control Facility (WSWPCF) and Affirmation of the City Manager's Actions Regarding Emergency Repairs (\$11,780)
 MEETING DATE: March 2, 2005
 PREPARED BY: Public Works Director

RECOMMENDED ACTION: That the City Council affirm the City Manager's actions regarding emergency repairs.

BACKGROUND INFORMATION: The Public Works Director has received approval from the City Manager for emergency repair work done without formal bid in the amount of \$11,780. The repair was to a turbine pump at the Facility. Due to the worn impeller shaft and impeller, the turbine pump was unable to maintain adequate flow volumes to insure proper levels in the emergency storage ponds. This function is essential to plant operations. The decision to move ahead with the repair work was deemed necessary to maintain effective operations. The work was charged to the Facility Operating Budget.

FUNDING: Facility O&M Budget: 170403.7331



Richard C. Prima, Jr.
Public Works Director

Prepared by Del Kerlin, Assistant Wastewater Treatment Superintendent
 RCP/DK/dk
 cc: Del Kerlin, Assistant Wastewater Treatment Superintendent
 Joel Harris, Purchasing Officer

APPROVED: 
 Blair King, City Manager