



**CITY OF LODI
COUNCIL COMMUNICATION**

AGENDA TITLE: Approve Plans and Specifications and Authorize Advertisement for Bids for White Slough Water Pollution Control Facility Holding Pond No. 1 Rehabilitation, 12751 North Thornton Road

MEETING DATE: February 15, 2006

PREPARED BY: Public Works Director

RECOMMENDED ACTION: That the City Council approve the plans and specifications for the above project and authorize advertising for bids.

BACKGROUND INFORMATION: This project consists of windrowing, aerating, and air drying approximately 25,000 cubic yards of eroded soil and organic material, in place, in the bottom of Holding Pond No. 1. The project also consists of loading, hauling, and placing the suitably dried material at a designated storage yard at the White Slough Water Pollution Control Facility.

The plans and specifications are on file in the Public Works Department

FISCAL IMPACT: Failure to perform this work will lead to decreased storage capacity in the pond, as well as permit violations due to over topping of the pond.

FUNDING AVAILABLE: The money for this project will be coming from the Wastewater Capital Fund. A request for appropriation of funds will be made at contract award.

Project Estimate: \$150,000
 Budgeted: 05/06 fiscal year
 Planned Bid Opening Date: March 7, 2006



 Ruby Parite, Interim Finance Director


 Richard C. Prima, Jr.
 Public Works Director

Prepared by Mark J. Lindseth, Associate Civil Engineer

RCP/MJL/pmf

cc: Joel Harris, Purchasing Officer
 Del Kerlin, Assistant Wastewater Treatment Superintendent

APPROVED: 
 Blair King, City Manager