



CITY OF LODI

COUNCIL COMMUNICATION

AGENDA TITLE: Consultant Agreement for Design of Dibromochloropropane (DBCP) Treatment Units at 200 West Century Boulevard, 601 West Harney Lane, 2126 West Kettleman Lane, 2040 South Cherokee Lane, and 55 East Harney Lane (Wells 18, 19, 20, 22 and 23)

MEETING DATE: February 19, 1992

PREPARED BY: Public Works Director

RECOMMENDED ACTION: That the City Council authorize the City Manager to execute a consultant agreement with the engineering firm of Brown 8 Caldwell for the design of granular activated carbon (GAC) DBCP treatment units for Wells 18, 19, 20, 22 and 23 and appropriate \$95,000 from the Water Capital Outlay Fund for this phase of the project.

BACKGROUND INFORMATION: The DBCP treatment study prepared by Brown 8 Caldwell (B 6 C) and approved by the State Department of Health Services calls for the use of granular activated carbon units to remove DBCP from City wells. B 6 C was selected to prepare the plans and specifications for the first GAC unit at Well 16. Their familiarity with Lodi's well sites and their previous experience in preparing plans and specifications for us will be very helpful in meeting the State mandated October 1992 deadline for the installation of these units.

The design cost for these five units is \$79,000 plus City staff time costs and miscellaneous expenses and contingencies for an estimated total of \$95,000.

FUNDING: Water Capital Outlay Fund.

Handwritten signature of Jack L. Ronsko and typed name: Jack L. Ronsko, Public Works Director

Prepared by Wesley K. Fujitani, Senior Civil Engineer

JLR/WKF/lm

cc: Water/Wastewater Superintendent Brown 8 Caldwell

APPROVED

Handwritten signature of Thomas A. Peterson

THOMAS A. PETERSON City Manager

CC:1