



CITY OF LODI

COMMUNICATION

COUNCIL

AGENDA TITLE: Plans and Specifications and Advertisement for Bids for DBCP Treatment Unit at Well #16, Century Boulevard and WID Canal

MEETING DATE: September 18, 1991

PREPARED BY: Public Works Director


RECOMMENDED ACTION: That the City Council approve the plans and specifications for the above project and authorize advertising for bids.

BACKGROUND INFORMATION: This project will install a state mandated granular activated carbon (GAC) filter system at Well #16. This filter system will remove DBCP to levels established in the state safe drinking water standards.

The State Department of Health Services has given the City of Lodi an April 1992 deadline to have one filter system installed and in operation. The design of the remaining filter units for the other "contaminated" wells will begin after the first system is in operation.

This project is financed under the California Safe Drinking Water Bond Law Program administered by the State of California, Department of Water Resources, and the State Department of Health Services. The state will reimburse the City upon submittal of the proper paperwork.

FUNDING:	Originally Budgeted:	1990
	Budgeted Fund:	California Safe Drinking Water Bond Law Program
	Total Project Estimate:	\$465,000
	Bid Opening Date:	10/16/91


 Jack L. Ronsko
 Public Works Director

Prepared by Wesley Fujitani, Senior Civil Engineer

JLR/WK/lm

cc: City Attorney
Purchasing Officer
Water/Wastewater Superintendent

APPROVED: 
 THOMAS A. PETERSON

