



CITY OF LODI

PUBLIC WORKS DEPARTMENT

COUNCIL COMMUNICATION

TO: City Council

FROM: City Manager

MEETING DATE: September 5, 1990


AGENDA TITLE: Plans and Specifications and Advertisement for Bids for Sacramento Street Water Main Improvements, Lodi Avenue to 250 Feet North of Lodi Avenue, Alley East of School Street Wastewater Improvements, 150 Feet South of Oak Street to Oak Street

Project Data
Total Project Estimate: \$33,000
Bid Opening Date: 9/26/90

RECOMMENDED ACTION: That the City Council approve the plans and specifications for the above project and authorize advertising for bids, and appropriate \$14,000 from the Water Capital Outlay (18.1) Fund and \$19,000 from the Wastewater Utility (17.1) Fund.

BACKGROUND INFORMATION: This project corrects two deficiencies in the downtown area. The new 8" water main in Sacramento Street will provide better water pressure to the businesses in this block. These businesses are currently tapped into a 2" water main. When 221 South Sacramento Street washes cherries during the spring season, there is such a draw in the 2" City main that the other businesses have no water pressure. The new water main will eliminate this problem.

The City has also had an ongoing problem with a public Wastewater main in the Post Office parking lot. A sag in this main cannot be fixed because it is located under a handicap ramp and a wall which was built with the Post Office remodel project. This project will reroute the upstream customers so that the City can abandon the problem wastewater main.


Jack L. Ronsko
Public Works Director

JLR/WK/mt

cc: Purchasing Officer
Water/Wastewater Superintendent

APPROVED:


THOMAS A. PETERSON, City Manager

FILE YO.