

CITY COUNCIL MEETING
SEPTEMBER 9, 1988

14

AWARD 61D FOR THE
PURCHASE OF POLE-
MOUNTED TRANSFORMERS

RES. NO. 88-119

CC-12(d)
CC-20
cc-47

The City Council was reminded that on August 3, 1988, it had approved specifications for the purchase of pole-mounted transformers, and authorized advertisement for bids. Bids were opened on August 23, 1988.

The transformers will be used for replacements in the PCB change-out program and to maintain an inventory for emergencies as they develop.

Transformers are evaluated by combining the purchase price with the cost of transformer losses to arrive at a total life-cycle cost. The cost of transformer losses is the dollar value assigned based on design data provided by the suppliers. The recommendation to award is then based on the minimum total life-cycle cost of units otherwise meeting specifications.

Funding for this purchase is available in the Electric Utility Department's Operating Fund.

A breakdown of the bids received was presented for the City Council's review.

The City Council adopted Resolution No. 88-119 awarding the bid for the purchase of single-phase Conventional and Circuit-Protected pole-mounted Transformers as follows:

<u>RTE CORPORATION</u>	<u>PURCHASE PRICE INC. TAX</u>
5 Ea 15 KVA CP 120/240 Volt	\$ 2,877.90
10 Ea 25 KVA CP 120/240 Volt	6,519.00
10 Ea 37.5 KVA CP 120/240 Volt	8,045.40
10 Ea 50 KVA CP 120/240 Volt	9,805.00
15 Ea 15 KVA Conv 120/240 Volt	7,504.80
10 Ea 25 KVA Conv 120/240 Volt	5,766.40
3 Ea 25 KVA Conv 277 Volt	1,752.18
10 Ea 37.5 KVA Conv 120/240 Volt	6,921.80
3 Ea 37.5 KVA Conv 277 Volt	2,337.30
15 Ea 50 KVA Conv 120/240 Volt	12,926.70
3 Ea 50 KVA Conv 277 Volt	2,464.50
1 Ea 167 KVA Conv 277 Volt	2,571.56
	\$69,492.54