

COUNCIL COMMUNICATION

TO: THE CITY COUNCIL	COUNCIL MEETING DATE	NO.
FROM: THE CITY MANAGER'S OFFICE	NOVEMBER 15, 1989	
SUBJECT: SPECIFICATIONS AND ADVERTISEMENT FOR THE PURCHASE OF WATTHOUR METERS		

RECOMMENDED ACTION: That the City Council approve the specifications for the purchase of 576 watthour meters and authorize advertisement for bids thereon.

The bid opening date has been scheduled for Tuesday, November 28, 1989.


BACKGROUND INFORMATION: The meters will be used to meter electric energy usage at the following developments:

Sunwest 9, 10 and 11  
Almond Drive Apartments  
Geweke Estates

In addition, the meters will be required for other smaller developments throughout the City, to maintain an inventory for other needs as they develop, and for replacement of obsolete and deteriorated meters located during meter testing.

The estimated cost of this purchase is \$19,000, with delivery expected about 8 weeks after placement of order.

Funding is available in the Electric Utility Department's operating fund.

  
\_\_\_\_\_  
Joel E. Harris  
Purchasing Officer

cc: Electric Utility Director  
Assistant Electric Utility Director  
Electrical Engineer  
Electric Meter Technician

## EQUIPMENT SPECIFICATIONS

### WATTHOUR METERS

#### 1.3 GENERAL

Meter shall be single-phase watthour with clock dial register, self-contained socket-type having a "Lexan" cover. A label marked "City of Lodi" and a sequential number beginning with 31360 shall be factory installed on each meter. Shipping boxes shall show on the outside the sequential number of the meters contained within.

#### 1.4 RATING

Form 2S, 4 terminal, 240 volt, 3 wire, Class 200, 5 dials, Kh 7.2, Test Amp 30, multiplying factor 1.