

CITY COUNCIL MEETING

January 7, 1981

CC-20
CC-47
220

SPECS FOR COUNCIL APPROVED SPECIFICATIONS FOR THE PURCHASE OF
SINGLE-PHASE TWENTY-THREE 200 KVAR SINGLE-PHASE CAPACITOR UNITS AND
CAPACITOR DIRECTED THE CITY'S PURCHASING AGENT TO ADVERTISE FOR
UNITS BIDS THEREON.
APPROVED

COUNCIL COMMUNICATION

TO: THE CITY COUNCIL

FROM: THE CITY MANAGER'S OFFICE

DATE

December 30, 1980


NO.

SUBJECT: Specifications for the purchase of Single-Phase Capacitor Units (UD-E81-1)

Specifications for the purchase of twenty-three 200 KVAR single-phase capacitor units are presented for Council's approval and permission to advertise for bids is requested.

These capacitors will be utilized as replacements for the City's remaining PCB filled capacitors. PCB has been classified as a hazardous substance and is governed by stringent clean-up and disposal requirements. Existing PCB filled capacitors are a potential liability to the City, in the event of a spill of the PCB fluid from a violent tank rupture, as such spills can be quite costly to clean up.

The bid opening date has been set for Tuesday, January 27, 1981. The estimated cost of this purchase is \$12,500.00, with delivery in approximately three months.



David K. Curry
Utility Director

Att.

DKC:HH:dw