

cc-4591

CITY COUNCIL MEETING

JANUARY 20, 1982

LIGHTING AT CITY
PARKING LOT
APPROVED

Following introduction of the matter by City Manager
Glaves, Council, on motion of Councilman Hughes,
Katnich second, approved the expenditure of \$1,200.00
for lighting at the City Parking lot located at the
Southeast corner of Elm and Sacramento Street.


MEMORANDUM

TO: PUBLIC WORKS DIRECTOR
FROM: UTILITY DIRECTOR
DATE: DECEMBER 24, 1981
SUBJECT: LIGHTING REQUEST FOR CITY PARKING LOT PER J.L.R. MEMO DATED
DECEMBER 21, 1981.

The estimated cost to provide adequate lighting for the parking lot located at the southeast corner of Elm and Sacramento Streets is \$1,200. The installation would consist of two wooden poles, each with a 100-watt sodium luminaire. The source of power would be overhead secondary distribution (see attached drawing for detail).


Should we assume that this lighting system can be installed without formal authorization from the property owner (S.P. Co.)?

I trust that you will process the special allocation for the necessary funds.



David K. Curry

Attach.



LEGEND

- ⊙ 100 watt HPS luminaire on 35' wood pole
- Existing wood pole
- #6 al triplex

MEMORANDUM, City of Lodi, Public Works Department

TO: City Manager ✓
Utility Director


FROM: Public Works Director

DATE: December 21, 1981

SUBJECT: Request for Lighting City Parking Lot at
Southeast Corner of Elm and Sacramento Streets

After the last Council meeting of December 16, 1981, Councilman Katnich, together with one other Councilman, requested that I do whatever was required to provide lighting at the subject parking lot. Attached is a map showing the location of this lot which is on Southern Pacific Railroad property.


If it is determined that lighting can and should be installed, the appropriate account number for charging the work is 10-504.01 "Maintenance Parking Lots." It should be pointed out that no funds for this installation have been budgeted. I'll be happy to process the necessary special allocation request once the cost is known.


Jack L. Ronsko
Public Works Director


Attachment

JLR/eeh

AVE




CHURCH



SCHOOL


~~CHURCH~~



PINE

ELM

SACRAMENTO




OUTHERN

PACIFIC

RAILROAD

COMPANY




MEMORANDUM

TO: PUBLIC WORKS DIRECTOR
FROM: UTILITY DIRECTOR
DATE: DECEMBER 24, 1981
SUBJECT: LIGHTING REQUEST FOR CITY PARKING LOT PER J.L.R. MEMO DATED
DECEMBER 21, 1981.

The estimated cost to provide adequate lighting for the parking lot located at the southeast corner of Elm and Sacramento Streets is \$1,200. The installation would consist of two wooden poles, each with a 100-watt sodium luminaire. The source of power would be overhead secondary distribution (see attached drawing for detail).


Should we assume that this lighting system can be installed without formal authorization from the property owner (S.P. Co.)?

I trust that you will process the special allocation for the necessary funds.




David K. Curry

Attach.




ELM STREET



SACRAMENTO STREET

MAIN STREET

PINE STREET



LEGEND

- 100 watt HPS luminaire on 35' wood pole
- Existing wood pole
- #6 Al triplex