

✓ CC 47
CC 12
CC 5/8

CITY COUNCIL MEETING
FEBRUARY 15, 1984

SPECS FOR 69-KV
OIL CIRCUIT
BREAKER AND
PADMOUNT
TRANSFORMERS
APPROVED

COUNCIL APPROVED THE FOLLOWING SPECIFICATIONS AND AUTHORIZED
THE ADVERTISING FOR BIDS THEREON:

- 1) One (1) 69-kv, 1200 amp. oil circuit breaker
- 2) Ten 50 KVA and twenty 75 KVA single-phase and one KVA
three-phase padmount transformers.

COUNCIL COMMUNICATION

TO: THE CITY COUNCIL

FROM: THE CITY MANAGER'S OFFICE

DATE

February 3, 1984


NO.

SUBJECT: SPECIFICATIONS FOR THE PURCHASE OF 69-KV OIL CIRCUIT BREAKER (UD-E84-2)

Specifications for the purchase of one (1) 69-kv, 1200 amp., oil circuit breaker are presented for Council's approval and permission to advertise for bids is requested. The bid opening date has been set for Tuesday, March 13, 1984.

The circuit breaker will be installed at Henning Substation as a part of the Phase 2 development now in progress.

The estimated cost of this purchase is \$33,500, funding for which is included in the current budget. Delivery is expected in approximately five months.



David K. Curry
Utility Director

Attach.