

CITY COUNCIL MEETING

MAY 6, 1981

*Page 414*  
*CC-47*

CLASS II  
SLURRY SEAL  
SPECS  
APPROVED *AW*

COUNCIL APPROVED THE SPECIFICATIONS FOR CLASS II  
SLURRY SEAL AND AUTHORIZED THE PURCHASING AGENT  
TO ADVERTISE FOR BIDS THEREON



# CITY OF LODI

## COUNCIL COMMUNICATION

TO: City Council  
FROM: City Manager  
DATE: April 28, 1981  
SUBJECT: Approval of Class II Slurry Seal Specifications

**RECOMMENDED ACTION:** That the City Council approve the specifications for Class II Slurry Seal and authorize the Purchasing Agent to advertise for bids to be received Wednesday, May 20, 1981.

**BACKGROUND INFORMATION:** Slurry sealing of City streets is done by contract. Approval of the specifications would provide for sealing of the remaining 40% of streets proposed for sealing in 1980-81 and the alleys that were affected by the construction of Downtown Underground V.

Quantity

Streets 156,935 S/F

  
Jack L. Ronsko  
Public Works Director

Attachment

cc: Bob Holm

JLR:sib

APPROVED:

HENRY A. GLAVES, City Manager

FILE NO.

NOTICE TO BIDDERS TO APPLY

CLASS II SLURRY SEAL

The City of Lodi invites sealed proposals to apply Class II Slurry Seal to City streets, conforming to specifications on file in the office of the Public Works Director, City Hall, Lodi, California where copies of said specifications may be inspected or obtained.

Sealed proposals shall be delivered to the Purchasing Agent at the City Hall, 221 West Pine Street, Lodi at or before

11:00 A.M., Wednesday, May 20, 1981

and will be opened on the above day and hour in the City Hall Council Chambers, City Hall, Lodi, California.

The City of Lodi reserves the right to reject any or all bids, or to accept other than the lowest bid.

Reference is hereby made to said specifications for further details, which specifications and this notice shall be considered part of any contract made pursuant thereto.

R. H. Holm  
Purchasing Agent

# NOTICE INVITING BIDS TO APPLY

## CLASS II SLURRY SEAL

Sealed proposals marked "Bid to Apply Class II Slurry Seal" will be received by the Purchasing Agent in his office, City Hall, 221 West Pine Street, Lodi, California 95240, until 11:00 a.m., on Wednesday, May 20, 1981, at which time they will be publicly opened and read.

### BID REQUIREMENTS

#### 1. General Description of the Work

The work to be done consists in general of sealing various streets, by placing a Class II Slurry Seal over existing pavement. Areas to be Slurry Sealed are shown on attached City of Lodi map.

#### 2. Specifications

Slurry Seal shall conform to the requirements of Section 37-2, State of California, Standard Specifications, January 1978. Mixing and placing of Slurry Seal shall conform to the requirements of Section 37-2, State of California, Standard Specifications, January 1978.

#### 3. Materials

3.1 Bituminous Binder shall be mixing type asphalt emulsion C SS-1 with grade 60-70 paving asphalt base (American Asphalt Institute designation C SS1-h Quickset Cationic Emulsion) conforming to section 94, standard specification.

#### 3.2 Application of Slurry Seal

The mixture shall be spread to an average thickness of 3/16" with a minimum thickness of not less than 1/8" and a maximum thickness not to exceed 1/4" and shall be placed at a rate of not less than 10 lbs. or more than 18 lbs. of aggregate per square yard.

#### 3.3 Aggregate shall conform to the following gradings:

<u>Sieve Size</u>	<u>Percentage Passing</u>
3/8	100
No. 4	90-100
No. 8	65-90
No. 16	40-70
No. 30	25-50
No. 200	5-15

4. Special Provisions

4.1 Surface Preparation

City of Lodi shall be responsible to flush, patch and crackfill streets prior to sealing.

4.2 Stockpile of Material

City of Lodi shall supply area to store aggregate required for sealing. Stockpile area shown on attached City map.

4.3 Weight Tags

City of Lodi shall be supplied a copy of the weight tags of the aggregate delivered to the stockpile.

4.4 Sieve Analysis

Successful bidder shall submit a sieve analysis by a certified testing laboratory prior to delivering aggregate to stockpile.

4.5 Notification of Residents

City of Lodi shall notify residents of street closure, date and time.

4.6 Protection of Utility Risers

City of Lodi shall oil all utility risers prior to sealing and clean lids after sealing.

4.7 Maintaining Traffic and Protection of Work Site

Contractor shall be responsible to furnish all barricades and signs to protect work site and safe passage of public traffic.

4.8 Beginning and Ending Limits of Work

Start and finish of Slurry application shall be a straight line obtained by laying a strip of building material and removing after Slurry Seal is applied.

Slurry Seal shall cover the crack between toe of gutter and pavement without protruding onto the concrete. No excessive build-up nor unsightly appearance shall be permitted on longitudinal or transverse joints.

4.9 The contract price of the Class II Slurry Seal shall include full compensation for furnishing all labor, material, tools and equipment to apply the Class II Slurry Seal and no additional compensation will be allowed therefore. This includes cleaning up all excess materials and protecting the Seal from traffic damage until the mixture is cured sufficiently so that material will not adhere to the tires of a vehicle.

4.10 Contractor shall complete work within 30 days after award of bid.

R.H. HOLM  
Purchasing Agent

4.9 The contract price of the Class II Slurry Seal shall include full compensation for furnishing all labor, material, tools and equipment to apply the Class II Slurry Seal and no additional compensation will be allowed therefore. This includes cleaning up all excess materials and protecting the Seal from traffic damage until the mixture is cured sufficiently so that material will not adhere to the tires of a vehicle.

4.10 Contractor shall complete work within 30 days after award of bid.

R.H. HOLM  
Purchasing Agent

BID PROPOSAL

CLASS II SLURRY SEAL

CITY OF LODI, CALIFORNIA

The undersigned declares that he has examined the bid requirements and submits the following bid:

Street Name	Boundry	Dimension	S/F	Cost Per S/F	Cost
Sperling Way	N/O First Street	30x150	4,500		
Cul-de-sac	N/O First Street	28x70	1,960		
First Street	Pleasant-California	31x1,250	38,750		
Park Street	Hutchins-Orange	30.5x600	18,300		
Orange Street	Park-York	30.5x250	7,625		
Kimberly Way	W/O Crescent	30x240	7,200		
Cul-de-sac	W/O Crescent	28x70	1,960		
Perry Way	W/O Crescent	30x240	7,200		
Cul-de-sac	W/O Crescent	28x70	1,960		
Crescent Avenue	Lockeford-Holly Dr.	30.5x 750	22,875		
Lincoln Street	First-Daisy	30x560	16,800		
Redwood	Stockton-Washington	23.5x630	14,805		
Alley	N/O Elm-E/O Church	20x650	13,000		

TOTAL S/F 156,935 TOTAL COST \_\_\_\_\_

CONTRACTOR \_\_\_\_\_

Address \_\_\_\_\_

By: \_\_\_\_\_

Title: \_\_\_\_\_

Date: \_\_\_\_\_