

CITY COUNCIL MEETING

June 3, 1981

Rec 432
CC-47

SPECS FOR
THREE-PHASE
PADMOUNTED
TRANSFORMER
APPROVED

SPECIFICATIONS FOR THE PURCHASE OF ONE 500 KVA
PADMOUNTED TRANSFORMER WERE APPROVED AND THE PURCHAS-
ING AGENT WAS AUTHORIZED TO ADVERTISE FOR BIDS
THEREON.

d
COUNCIL COMMUNICATION

TO: THE CITY COUNCIL

DATE

NO.

FROM: THE CITY MANAGER'S OFFICE

May 29, 1981

SUBJECT: SPECIFICATIONS FOR THE PURCHASE OF THREE-PHASE PADMOUNTED TRANSFORMER (UD-E81-3)

Specifications for the purchase of one 500 KVA padmounted transformer are presented for Council's approval and permission to advertise for bids is requested. The bid opening date has been set for Tuesday, June 23, 1981.

The transformer will be used to replace an existing 300 KVA transformer at Sun World on North Stockton Street, as a result of increased loading at that facility.

The estimated cost of this purchase is \$7,000 with delivery expected in approximately four months.



David K. Curry
Utility Director

Attach.