



CITY OF LODI COUNCIL COMMUNICATION

TM

AGENDA TITLE: Receive Report on Resolution of Public Works Emergency Requiring the Immediate Repair of Blakely Pool Circulation System

MEETING DATE: June 5, 2013

PREPARED BY: Parks, Recreation and Cultural Services Director


RECOMMENDED ACTION: Receive report on resolution of the Public Works Emergency requiring the immediate repair of the Blakely Pool circulation system.

BACKGROUND INFORMATION: On April 3, 2013, the City Council made a finding that a public works emergency existed at the south pool at the Blakely Park pool complex, due to a massive leak (8,000 gallons per day) suspected in the circulation system. The council authorized the City Manager to execute a contract with Paragon Pools in an amount not to exceed \$20,000 and begin repair work as soon as possible. On May 1, 2013, the City Council declared the emergency continues to exist, as repairs had not been completed, and the City Council made the same declaration on May 15, 2013.

Repairs were completed last week at a cost of \$17,500. Three leaks below-ground leaks were detected, including one that had created a significant void beneath the concrete pool deck. In addition, one of the circulation pipes had collapsed. A large portion of the circulation system was being replaced because of this damage. The 50-year-old-plus metal circulation system was replaced, and the pool deck removed for the work was replaced by new concrete tied into the existing deck with rebar.


FISCAL IMPACT: \$17,500 from the FY 2012/13 PRCS operating budget.

FUNDING AVAILABLE: PRCS 347215.7335 (General Activities & Events)



Jeff Hood
Parks, Recreation and Cultural Services Director

APPROVED:



Konradt Bartlam, City Manager