

## CITY COUNCIL MEETING

JUNE 14, 1981

AWARD -  
THREE-PHASE  
PADMOUNT  
TRANSFORMER

Council was apprised that the following bids had been received for a three-phase padmount transformer to replace the failing unit at Lodi High School:

RES. NO. 81-79

Supplier - General Electric Supply Co.

"A" Price w/tax	\$ 9,540.00
"B" Cost of Losses	\$ 7,082.00
"A" + "B" Life-Cycle Cost	\$16,622.00
Estimated Delivery (weeks)	14-16
Comments	Does not meet City Specifications

Supplier - RTE Corporation

"A" Price w/tax	\$ 8,453.50
"B" Cost of Losses	\$ 8,381.50
"A" + "B" Life-Cycle Cost	\$16,835.00
Estimated Delivery (weeks)	11-12

Supplier - Westinghouse Elec. Supply Co.

"A" Price w/tax	\$14,149.94
"B" Cost of Losses	\$ 6,725.00
"A" + "B" Life-Cycle Cost	\$20,874.94
Estimated Delivery (weeks)	17

Supplier - Kuhlman Electric Co.

"A" Price w/tax	\$13,960.20
"B" Cost of Losses	\$7,775.00
"A" + "B" Life-Cycle Cost	\$21,735.20
Estimated Delivery (weeks)	12-13

Supplier - Valley Electric Co.

"A" Price w/tax	\$13,546.80
"B" Cost of Losses	\$10,525.00
"A" + "B" Life-Cycle Cost	\$24,071.80
Estimated Delivery (weeks)	10-12

On motion of Councilman Katnich, Hughes second, Council adopted Resolution No. 81-79 awarding the bid for one 750 KVA, three-phase padmount transformer to replace the failing unit at Lodi High School to RTE Corporation in the amount of \$8,453.50, the lowest bidder meeting City specifications.

THREE-PHASE PADMOUNT TRANSFORMER BID EVALUATION

UD-E81-2

<u>Supplier</u>	<u>"A" Price w/tax</u>	<u>"B" Cost of Losses</u>	<u>"A" + "B" Life-Cycle Cost</u>	<u>Estimated Delivery (weeks)</u>	<u>Comments</u>
General Electric Supply Co. Emeryville	\$ 9,540.00	\$ 7,082.00	\$16,622.00	14-16	Does not meet City Specifications.
RTE Corporation Waukesha, WI	<u>8,453.50</u>	8,381.50	16,835.00	11-12	
Westinghouse Elec. Supply Co. Modesto	14,149.94	6,725.00	20,874.94	17	
Kuhlman Electric Co. Foster City	13,960.20	7,775.00	21,735.20	12-13	
Valley Electric Co. Stockton	13,546.80	10,525.00	24,071.80	10-12	

# COUNCIL COMMUNICATION

TO: THE CITY COUNCIL

DATE

NO.


FROM: THE CITY MANAGER'S OFFICE

June 12, 1981

SUBJECT: THREE-PHASE PADMOUNT TRANSFORMER BID (UD-E81-2)

On Tuesday, June 9, 1981, bids were received for one 750 KVA, three-phase padmount transformer, to replace the failing unit at Lodi High School. A summary of the bids is shown on the attached recap sheet.

Based on design data supplied by the bidders, the life-cycle cost of transformer losses has been evaluated. Column "B" is the dollar value associated with these losses. Based on minimum total life-cycle cost of the transformer, it is recommended that the bid be awarded to RTE Corporation in the amount of \$8,453.50, the lowest bidder meeting City specifications.

  
\_\_\_\_\_  
David K. Curry  
Utility Director

Attach.

RESOLUTION NO. 81-79

AWARD - THREE-PHASE PADMOUNT TRANSFORMER

WHEREAS, in answer to notice duly published in accordance with law and the order of this City Council, sealed bids were received and publicly opened by the City Clerk of this City on June 9, 1981 at 11:00 a.m. for the contract for Three-Phase Padmount Transformer as described in the specifications therefor approved by the City Council May 20, 1981; and

WHEREAS, said bids have been compared, checked, and tabulated and a report thereof filed with the City Manager as shown on Exhibit "A" attached hereto and thereby made a part hereof

WHEREAS, the City Manager recommends that award be made to the low bidder, RTE Corporation

NOW, THEREFORE, BE IT RESOLVED by the City Council of the City of Lodi that award of contract for Three-Phase Padmount Transformer be and the same is hereby made to RTE Corporation, the low bidder, in the amount of \$8,453.50.


Dated: June 17, 1981

I hereby certify that Resolution No. 81-79 was passed and adopted by the City Council of the City of Lodi in a regular meeting held June 17, 1981 by the following vote:

Ayes: Councilmen - Hughes, Katnich and McCarty

Noes: Councilmen - None

Absent: Councilmen - Murphy and Pinkerton

  
ALICE M. REIMCHE  
City Clerk

THREE-PHASE PADMOUNT TRANSFORMER BID EVALUATION

UD-E81-2

<u>Supplier</u>	<u>"A" Price w/tax</u>	<u>"B" Cost of Losses</u>	<u>"A" + "B" Life-Cycle Cost</u>	<u>Estimated Delivery (weeks)</u>	<u>Comments</u>
General Electric Supply Co. Emeryville	\$ 9,540.00	\$ 7,082.00	\$16,622.00	14-16	Does not meet City Specifications.
RTE Corporation Waukesha, WI	<u>8,453.50</u>	8,381.50	16,835.00	11-12	
Westinghouse Elec. Supply Co. Modesto	14,149.94	6,725.00	20,874.94	17	
Kuhlman Electric Co. Foster City	13,960.20	7,775.00	21,735.20	12-13	
Valley Electric Co. Stockton	13,546.80	10,525.00	24,071.80	10-12	