

CITY COUNCIL MEETING
AUGUST 15, 1984

cc 20
cc 47
AWARD - 5"
HOSE FOR
FIRE DEPT.

City Manager Graves presented the following bids which had been received for 5" hose for the Fire Department advising that 1) documents supporting manufacturer's data indicated an abrasion test of 20,000 cycles using a B22 wheel. Manufacturer does claim that this is a typographical error and should read as specified. Note: This data sheet is dated May 1984 and is the second document received containing an abrasion test of 20,000 cycles using a B22 wheel. 2) Control sample supplied by manufacturer is not a sample of material to be delivered as required in specifications. 3) Low bidder has not begun production of hose meeting specifications. The City of Lodi would be the first to receive this new product line. 4) Without a sample of proposed hose, no determination can be made concerning the ability to meet specifications. 5) The difference in bid price is \$42.50. 6) Hose to be supplied by Halprin Supply Company is a known product.

RES. NO.
84-124

Following discussion, Council, on motion of Council Member Pinkerton, Hinchman second, adopted Resolution No. 84-124 awarding the bid for 5" hose for the Fire Department to Halprin Supply Company in the amount of \$14,755.20, which represents the lowest responsible bid.

COUNCIL COMMUNICATION

TO THE CITY COUNCIL
FROM THE CITY MANAGER'S OFFICE

DATE
August 8, 1984

NO.


SUBJECT AWARDING OF BID FOR 5" HOSE

The bids received were as follows:

1. L.N. Curtis & Sons	\$ 14,712.80
2. Halprin Supply Company	14,755.20
3. Angus Fire Armour Corp.	21,952.00
4. American Rubber	-- No Bid --

It is recommended that the bid be awarded to Halprin Supply Company for the following reasons:

1. Documents supporting manufacturer's data indicated an abrasion test of 20,000 cycles using a B22 wheel. Manufacturer does claim that this is a typographical error and should read as specified.
Note: This data sheet is dated May 1984 and is the second document received containing an abrasion test of 20,000 cycles using a B22 wheel.
2. Control sample supplied by manufacturer is not a sample of material to be delivered as required in specifications.
3. Low bidder has not begun production of hose meeting specifications. The City of Lodi would be the first to receive this new product line.
4. Without a sample of proposed hose, no determination can be made concerning the ability to meet specifications.
5. The difference in bid price is \$42.40.
6. Hose to be supplied by Halprin Supply Company is a known product.



Steven W. Raddigan
Fire Administrative Officer

RESOLUTION NO. 84-124

AWARD - BID FOR 5" HOSE FOR FIRE DEPARTMENT

WHEREAS, in answer to notice duly published in accordance with law and the order of this City Council, sealed bids were received and publicly opened by the City Clerk of this City on July 31, 1984 at 11:00 a.m. for the contract for 5" Hose for Fire Department as described in the specifications therefor approved by the City Council July 5, 1984; and

WHEREAS, said bids have been compared, checked, and tabulated and a report thereof filed with the City Manager as follows:

<u>BIDDER</u>	<u>AMOUNT</u>
Angus Fire Armour Corp.	\$21,952.00
Halprin Supply Co.	\$14,755.20
L. N. Curtis & Sons	\$14,712.80
American Rubber Mfg. Co.	No Bid

WHEREAS, the City Manager recommends that award be made to Halprin Supply Co., the most responsible low bidder

NOW, THEREFORE, BE IT RESOLVED by the City Council of the City of Lodi that award of contract for 5" Inch Fire Hose for the Fire Department be and the same is hereby made to Halprin Supply Co., the most responsible low bidder, in the amount of \$14,755.20.

Dated: August 15, 1984

I hereby certify that Resolution No. 84-124 was passed and adopted by the City Council of the City of Lodi in a regular meeting held August 15, 1984 by the following vote:

Ayes: Council Members - Hinchman, Pinkerton, Olson, Reid, and Snider (Mayor)

Noes: Council Members - None

Absent: Council Members - None

Alice M. Reimche
ALICE M. REIMCHE
City Clerk