

CITY COUNCIL MEETING  
OCTOBER 17, 1984

84-155  
Job - CC 47

AWARD - PURCHASE  
OF THREE-PHASE  
PADMOUNT SWITCH-  
GEAR

City Manager Graves presented the following bids which had been received for one three-phase padmount vacuum switchgear:

<u>Bidder</u>	<u>Bid</u>
RTE Corporation	\$9,464.74
A.B.Chance Co.	\$11,906.34
Trayer Engineering Corp.	\$15,093.34

RES. NO. 84-155

COUNCIL ADOPTED RESOLUTION NO. 84-155 AWARDED THE BID FOR THE PURCHASE OF ONE THREE PHASE PADMOUNT VACUUM SWITCHGEAR TO R.T.E. CORPORATION, THE LOW BIDDER, IN THE AMOUNT OF \$9,464.74.

RESOLUTION NO. 84-155

AWARD - PURCHASE OF ONE THREE PHASE  
PADMOUNT VACUUM SWITCHGEAR

WHEREAS, in answer to notice duly published in accordance with law and the order of this City Council, sealed bids were received and publicly opened by the City Clerk of this City on October 2, 1984 at 11:00 a.m. for the contract for One Three Phase Padmount Vacuum Switchgear as described in the specifications therefor approved by the City Council September 5, 1984; and

WHEREAS, said bids have been compared, checked, and tabulated and a report thereof filed with the City Manager as follows:

<u>BIDDER</u>	<u>AMOUNT</u>
Trayer Eng. Corp.	\$15,093.00
A.B. Chance Co.	\$11,906.34
R.T.E. Corp.	\$ 9,464.74

WHEREAS, the City Manager recommends that award be made to the low bidder, R.T.E. Corp.

NOW, THEREFORE, BE IT RESOLVED by the City Council of the City of Lodi that award of contract for One Three Phase Padmount Vacuum Switchgear be and the same is hereby made to R.T.E. Corp., the low bidder, in the amount of \$9,464.74

Dated: October 17, 1984

I hereby certify that Resolution No. 84-155 was passed and adopted by the City Council of the City of Lodi in a regular meeting held October 17, 1984 by the following vote:

Ayes: Council Members - Pinkerton, Hinchman,  
Olson, Reid & Snider

Noes: Council Members - None

Absent: Council Members - None

*Alice M. Reimche*  
ALICE M. REIMCHE  
City Clerk

**AWARD - BID FOR  
PURCHASE OF  
THREE-PHASE  
PADMOUNT  
TRANSFORMERS**

RES. NO. 84-163

City Manager Graves presented the following bids which had been received for Three-phase Padmount Transformers:

SEE PAGE NO. 13

Following discussion, on motion of Mayor Pro Tempore Hinchman, Olson second, Council adopted Resolution No. 84-163 awarding the bid for the purchase of Three-Phase Padmount Transformers to Westinghouse Electric Supply Co., the low bidder, in the amount of \$20,913.80. This bid was for two 112½ KVA, one 150 KVA and one 300 KVA three-phase padmount transformers.

THREE-PHASE PADMOUNT TRANSFORMER BID EVALUATION

10-28-84

Supplier	2 - 112½ KVA (208 volts)				2 - 300 KVA (208 volts)				1 - 150 KVA (480 volts)			
	'A' Price w/Tax	'B' Cost of Losses	'A' + 'B' Life-Cycle Cost	Est. Del. Weeks	'A' Price w/Tax	'B' Cost of Losses	'A' + 'B' Life-Cycle Cost	Est. Del. Weeks	'A' Price w/Tax	'B' Cost of Losses	'A' + 'B' Life-Cycle Cost	Est. Del. Weeks
Westinghouse Elec. Supply Co. Concord, CA	96,378.66	83,820.40	180,199.06	23-25	910,362.56	7,087.50	917,450.06	23-25	93,828.60	92,215.35	186,043.95	23-25
RTE Corporation Vashburne, VT	7,897.00	3,655.00	11,552.00	19	11,717.26	7,387.10	19,104.36	20	4,426.44	2,218.60	6,645.04	19
Square D Company Monroe, NC	8,215.00	3,736.00	11,951.00	30	12,336.76	7,635.50	20,012.26	20	4,467.90	2,223.00	6,690.90	20
Madison Edison Co. Burlington, CA	7,137.44	5,666.60	12,794.04	21	10,258.68	11,783.60	22,042.28	21	3,985.60	3,515.35	7,500.95	21
General Elec. Supply Emeryville, CA	9,337.68	3,898.00	13,235.68	16-18	12,020.40	8,529.70	20,550.10	16-18	5,294.70	2,097.05	7,391.75	16-18

# UNCIL COMMUNICATION

TO THE CITY COUNCIL  
FROM THE CITY MANAGER'S OFFICE

DATE  
October 8, 1984

NO.

SUBJECT: PURCHASE OF THREE-PHASE PADMOUNT SWITCHGEAR (UD-E84-7)

On Tuesday, October 2, 1984, bids were received for one three-phase padmount vacuum switchgear. The switchgear will be used to provide a feed point for the Woodlake North Subdivision and for sectionalizing of a main feeder.

Based on the bids received, it is recommended that the bid be awarded to the low bidder, RTE Corporation, Waukesha, in the amount of \$9,464.74.



David K. Curry  
Utility Director

Attach.

BID EVALUATION

THREE-PHASE PADMOUNT SWITCHGEAR

UD-E84-7

<u>Supplier</u>	<u>Price Incl. Tax</u>	<u>Delivery</u>
RTE Corporation Waukesha, WI	\$ <u>9,464.74</u>	13-15 weeks
A.B. Chance Co. San Jose, CA	11,906.34	8-10 weeks
Trayer Engineering Corp. San Francisco, CA	15,093.34	20-24 weeks

RESOLUTION NO. 84-163

AWARD - BID FOR PURCHASE OF THREE PHASE  
PADMOUNT TRANSFORMERS

WHEREAS, in answer to notice duly published in accordance with law and the order of this City Council, sealed bids were received and publicly opened by the City Clerk of this City on October 2, 1984 at 11:00 a.m. for the contract for purchase of Three Phase Padmount Transformers as described in the specifications therefor approved by the City Council September 5, 1984; and

WHEREAS, said bids have been compared, checked, and tabulated and a report thereof filed with the City Manager as follows:

<u>BIDDER</u>	<u>AMOUNT</u>		
	Item 1	Item 2	Item 3
R.T.E. Corp	\$7,897.00	\$5,858.62	\$4,424.44
Westinghouse	\$6,724.64	\$5,181.28	\$3,828.60
G. E.	\$9,357.68	\$6,010.20	\$5,294.70
Square D	\$8,215.00	\$6,278.38	\$4,467.90
McGraw Edison	\$7,127.00	\$5,129.00	\$3,986.00

WHEREAS, the City Manager recommends that award be made to the low bidder, Westinghouse Electric Supply, Co.

NOW, THEREFORE, BE IT RESOLVED by the City Council of the City of Lodi that award of contract for Three Phase Padmount Transformers be and the same is hereby made to Westinghouse Electric Supply, Co., the low bidder, in the amount of \$20,913.80.

Dated: October 17, 1984

I hereby certify that Resolution No. 84-163 was passed and adopted by the City Council of the City of Lodi in a regular meeting held October 17, 1984 by the following vote:

Ayes: Council Members - Hinchman, Pinkerton, Reid, Olson, & Snider (Mayor)

Noes: Council Members - None

Absent: Council Members - None

  
ALICE M. REIMCHE  
City Clerk

THREE-PHASE PADMOUNT TRANSFORMER BID EVALUATION

UD-E84-8


Supplier	<u>2 - 112½ KVA (208 volt)</u>				<u>2 - 300 KVA (208 volt)</u>				<u>1 - 150 KVA (480 volt)</u>			
	<u>'A'</u> <u>Price</u> <u>w/Tax</u>	<u>'B'</u> <u>Cost of</u> <u>Losses</u>	<u>'A' + 'B'</u> <u>Life-Cycle</u> <u>Cost</u>	<u>Est.</u> <u>Del.</u> <u>Weeks</u>	<u>'A'</u> <u>Price</u> <u>w/Tax</u>	<u>'B'</u> <u>Cost of</u> <u>Losses</u>	<u>'A' + 'B'</u> <u>Life-Cycle</u> <u>Cost</u>	<u>Est.</u> <u>Del.</u> <u>Weeks</u>	<u>'A'</u> <u>Price</u> <u>w/Tax</u>	<u>'B'</u> <u>Cost of</u> <u>Losses</u>	<u>'A' + 'B'</u> <u>Life-Cycle</u> <u>Cost</u>	<u>Est.</u> <u>Del.</u> <u>Weeks</u>
Westinghouse Elec. Supply Co. Concord, CA	<u>\$6,724.64</u>	\$3,820.40	\$10,545.04	23-25	<u>\$10,362.56</u>	\$ 7,887.50	\$18,250.06	23-25	<u>\$3,826.60</u>	\$2,215.35	\$6,041.95	23-25
RTE Corporation Waukesha, WI	7,897.00	3,655.00	11,552.00	19	11,717.24	7,387.10	19,104.34	20	4,424.44	2,218.60	6,643.04	19
Square D Company Monroe, NC	8,215.00	3,736.00	11,951.00	20	12,556.76	7,655.50	20,212.26	20	4,467.90	2,223.00	6,690.90	20
McGraw Edison Co. Burlingame, CA	7,127.44	5,666.60	12,794.04	21	10,258.68	11,783.40	22,042.08	21	3,985.60	3,515.35	7,500.95	21
General Elec. Supply Emeryville, CA	9,357.68	3,898.00	13,255.68	16-13	12,020.40	8,529.70	20,550.10	16-18	5,294.70	2,097.05	7,391.75	16-18

# COUNCIL COMMUNICATION

TO THE CITY COUNCIL FROM THE CITY MANAGER'S OFFICE	DATE October 10, 1984	NO.
SUBJECT: PURCHASE OF THREE-PHASE PADMOUNT TRANSFORMERS (UD-E84-8)		

On Tuesday, October 2, 1984, bids were received for two 112½ KVA, one 150 KVA and one 300 KVA three-phase padmount transformers. The transformers will be utilized at Community Drive Medical Offices, Quashnick Tool and Arbor Apartments. During the bidding process, the need for one additional 300 KVA unit to serve the Locust Square project has developed. It is requested that this unit be awarded on this bid, as well.

Based on design data supplied by the bidders, the life-cycle cost of transformer losses has been evaluated. Column 'B' is the dollar value associated with these losses. Based on minimum total life-cycle cost of the transformers, it is recommended that the bid be awarded to the lowest bidder, Westinghouse Electric Supply Co., Concord, in the amount of \$20,913.80.

  
\_\_\_\_\_  
David K. Curry  
Utility Director

Attach.

THREE-PHASE PADMOUNT TRANSFORMER BID EVALUATION

UD-E84-8

Supplier	<u>2 - 112½ KVA (208 volt)</u>				<u>2 - 300 KVA (208 volt)</u>				<u>1 - 150 KVA (480 volt)</u>			
	<u>'A'</u> <u>Price</u> <u>w/Tax</u>	<u>'B'</u> <u>Cost of</u> <u>Losses</u>	<u>'A' + 'B'</u> <u>Life-Cycle</u> <u>Cost</u>	<u>Est.</u> <u>Del.</u> <u>Weeks</u>	<u>'A'</u> <u>Price</u> <u>w/Tax</u>	<u>'B'</u> <u>Cost of</u> <u>Losses</u>	<u>'A' + 'B'</u> <u>Life-Cycle</u> <u>Cost</u>	<u>Est.</u> <u>Del.</u> <u>Weeks</u>	<u>'A'</u> <u>Price</u> <u>w/Tax</u>	<u>'B'</u> <u>Cost of</u> <u>Losses</u>	<u>'A' + 'B'</u> <u>Life-Cycle</u> <u>Cost</u>	<u>Est.</u> <u>Del.</u> <u>Weeks</u>
Westinghouse Elec. Supply Co. Concord, CA	<u>\$6,724.64</u>	\$3,820.40	\$10,545.04	23-25	<u>\$10,362.56</u>	\$ 7,887.50	\$18,250.06	23-25	<u>\$3,826.60</u>	\$2,215.35	\$6,041.95	23-25
RTE Corporation Waukesha, WI	7,897.00	3,655.00	11,552.00	19	11,717.24	7,387.10	19,104.34	20	4,424.44	2,218.60	6,543.04	19
Square D Company Monroe, NC	8,215.00	3,736.00	11,951.00	20	12,556.76	7,655.50	20,212.26	20	4,467.90	2,223.00	6,690.90	20
McGraw Edison Co. Burlingame, CA	7,127.44	5,666.60	12,794.04	21	10,258.68	11,783.40	22,042.08	21	3,985.60	3,515.35	7,500.95	21
General Elec. Supply Emeryville, CA	9,357.68	3,898.00	13,255.68	16-18	12,020.40	8,529.70	20,550.10	16-18	5,294.70	2,097.05	7,391.75	16-18