

RESOLUTION NO. 98-58

A RESOLUTION OF THE LODI CITY COUNCIL
AWARDING THE BID FOR THE PURCHASE OF FIVE
PADMOUNT TRANSFORMERS

=====

WHEREAS; in answer to notice duly published in accordance with law and the order of this City Council, sealed bids were received and publicly opened on April 1, 1998 at 2:00 p.m. for the purchase of five padmount transformers for the Electric Utility Department, described in the specifications therefore approved by the City Council on November 19, 1997; and

WHEREAS, said bids have been compared, checked, and tabulated and a report thereof filed with the City Manager as shown on Exhibit A attached hereto; and

WHEREAS, the City Manager recommends that award of the bid for the purchase of five padmount transformers for the Electric Utility Department, be made to the bidders whose proposals and equipment met City of Lodi specifications, and whose transformers yielded the lowest overall life-cycle costs in each rating category, to wit:

Kuhlman Electric, Versailles, KY	2 ea.	167KVA 1Ø	\$ 4,773.33
Howard Industries, Laurel MS	1 ea.	75KVA 3Ø	\$ 3,597.77
Western States Electric, Portland, OR	2 ea.	1500KVA 3Ø	<u>\$34,900.23</u>
			\$43,271.33


NOW, THEREFORE, BE IT RESOLVED by the Lodi City Council that the award of the purchase of five padmount transformers for the Electric Utility Department, be and the same is hereby awarded to the above-described responsible bidders, in the total amount of \$43,271.33.

Dated: April 15, 1998

=====

I hereby certify that Resolution No. 98-58 was passed and adopted by the City Council of the City of Lodi in a regular meeting held April 15, 1998, by the following vote:

- AYES: COUNCIL MEMBERS - Johnson, Land, Mann, Pennino and Sieglock (Mayor)
- NOES: COUNCIL MEMBERS - None
- ABSENT: COUNCIL MEMBERS - None
- ABSTAIN: COUNCIL MEMBERS - None


ALICE M. REIMCHE
City Clerk

TRANSFORMER BID EVALUATION

Bid Opening: April 1, 1998

EXHIBIT A

April 1, 1998

Tax (factor) 1.0775
 No load loss \$/watt 6.00
 Load loss \$/watt 2.00

187 KVA, 240/120 Volt, Single Phase Pads

Number of units: 2

Vendor	Unit Price	Extended Price	Price w/tax	No load loss (watts)	Load loss (watts)	No load loss value	Load loss value	Cost of Losses	Life cycle Cost	Delivery weeks	Height	Weight
Kuhlman	2,215.00	4,430.00	4,773.33	277	933	3,324.00	3,732.00	7,056.00	11,829.33	7	27	
Central Moloney	2,060.00	4,120.00	4,439.30	257	1082	3,084.00	4,328.00	7,412.00	11,851.30	9	32	
Howard Industries	2,494.00	4,988.00	5,374.57	246	923	2,952.00	3,692.00	6,644.00	12,018.57	14-16	28	
Cooper	1,799.00	3,598.00	3,876.85	247	1950	2,964.00	7,800.00	10,764.00	14,840.85	18	30	
GE Supply	No Bid											
Western States	No Bid											

75 KVA, 480Y/277 Volt, Three Phase Pad

Number of units: 1

Vendor	Unit Price	Extended Price	Price w/tax	No load loss (watts)	Load loss (watts)	No load loss value	Load loss value	Cost of Losses	Life cycle Cost	Delivery weeks	Height	Weight
Howard Industries	3,339.00	3,339.00	3,597.77	172	585	1,032.00	1,170.00	2,202.00	5,799.77	21-23	51	
Western States	3,665.00	3,665.00	3,949.04	182	544	1,092.00	1,088.00	2,180.00	6,129.04	20-22	58	
Cooper	3,617.00	3,617.00	3,897.32	195	592	1,170.00	1,184.00	2,354.00	6,251.32	12	50	
GE Supply	4,773.00	4,773.00	5,142.91	80	458	480.00	916.00	1,396.00	6,538.91	13-15	61	
Central Moloney	No Bid											
Kuhlman	No Bid											

1,500 KVA, 480Y/277 Volt, Three Phase Pads

Number of units: 2

Vendor	Unit Price	Extended Price	Price w/tax	No load loss (watts)	Load loss (watts)	No load loss value	Load loss value	Cost of Losses	Life cycle Cost	Delivery weeks	Height	Weight
Western States	16,195.00	32,390.00	34,900.23	1259	7043	15,108.00	28,172.00	43,280.00	78,180.23	20-22	72	
GE Supply	18,740.00	37,480.00	40,384.70	554	8623	6,648.00	34,492.00	41,140.00	81,524.70	13-15	89	
Howard Industries	17,005.00	34,010.00	36,845.78	1437	7782	17,244.00	31,128.00	48,372.00	85,017.78	21-23	75	
Cooper	17,461.00	34,922.00	37,828.48	1499	8637	17,988.00	34,548.00	52,536.00	90,164.48	12	72	
Central Moloney	No Bid											
Kuhlman	No Bid											