

RESOLUTION NO. 90-28

=====

A RESOLUTION OF THE LODI CITY COUNCIL
AWARDING THE BID FOR PURCHASE OF 19 PAD-MOUNTED TRANSFORMERS

=====

WHEREAS, in answer to notice duly published in accordance with law and the order of this City Council, sealed bids were received and publicly opened on February 20, 1990 at 11:00 a.m. for the bid for the purchase of 19 pad-mounted transformers, described in the specifications therefor approved by the City Council on January 17, 1990; and

WHEREAS, said bids have been compared, checked, and tabulated and a report thereof filed with the City Manager as shown on Attachment 1;

WHEREAS, the City Manager recommends that award of the bids for the purchase of 19 pad-mounted transformers, be made to the best qualifying bidders as follows:

<u>Westinghouse Utilities, Concord</u>		
5 ea 37.5 KVA Single-phase		\$ 6,215.63
2 ea 50 KVA Single-phase		3,006.88
6 ea 100 KVA Single-phase		11,188.13
1 ea 150 KVA Three-phase		4,749.38
3 ea 300 KVA Three-phase		18,423.75
		=====
	TOTAL	\$43,583.77
 <u>Cooper Power Systems, Burlingame</u>		
2 ea 112.5 KVA Three-phase		\$ 7,945.38

NOW, THEREFORE, BE IT RESOLVED by the City Council of the City of Lodi that award of bid for the purchase of 19 pad-mounted transformers be and the same is hereby awarded to Westinghouse Utilities, Concord, and Cooper Power Systems, Burlingame, the best qualifying bidders as outlined above, in the amounts of \$43,583.77 and \$7,945.38 respectively.

Dated: March 7, 1990

=====

I hereby certify that Resolution No. 90-28 was passed and adopted by the City Council of the City of Lodi in a regular meeting held March 7, 1990 by the following vote:

Ayes: Council Members - Hinchman, Olson, Pinkerton, Reid and Snider (Mayor)

Noes: Council Members - None

Absent: Council Members - None


Alice M. Reimche
City Clerk

SUMMARY
BIDS RECEIVED*/LIFE CYCLE COSTS
PADMOUNTED TRANSFORMERS
BID OPENING FEBRUARY 20, 1990

TRANSFORMER DESCRIPTION	WESTINGHOUSE CONCORD	COOPER POWER BURLINGAME	CEN. MOLONEY ARKANSAS	WEST. STATES PORTLAND	GEN'L ELECT. EMERYVILLE	MAYD.&HART BRISBANE	PAUWELS TRF. MISSOURI
	-----	-----	-----	-----	-----	-----	-----
			(1)	(2)	(3)		(4)
<u>SINGLE-PHASE PADMOUNTED:</u>							
5 EA 37.5KVA, 240/120V	\$6,215.63/ <u>\$11,305.63</u>	\$6,125.31/ \$11,585.31	\$5,121.25/ \$11,821.25	NO BID	\$9,832.17/ \$13,032.17	\$ 5,795.94/ \$11,595.94	NO BID
2 EA 50KVA, 240/120V	\$3,006.88/ <u>\$5,270.88</u>	\$2,730.63/ \$5,586.63	\$2,828.38/ \$5,648.38	\$3,436.13/ \$6,040.13	\$3,777.45/ \$5,957.45	\$ 2,717.88/ \$ 5,573.88	NO BID
6 EA 100KVA, 240/120V	\$11,188.13/ <u>\$26,116.13</u>	\$14,401.13/ \$28,441.13	\$10,710.00/ \$26,322.00	\$12,252.75/ \$26,904.75	\$13,204.16/ \$28,540.16	\$11,194.50/ \$27,010.50	NO BID
<u>THREE-PHASE PADMOUNTED:</u>							
2 EA 112.5KVA, 208/120V	\$8,589.25/ \$14,757.25	\$7,945.38/ <u>\$14,725.38</u>	NO BID	NO BID	\$10,269.15/ \$16,533.15	\$ 7,949.63/ \$15,089.63	\$ 6,806.38/ \$14,958.38
1 EA 150KVA, 408/277V	\$4,749.38/ <u>\$8,301.38</u>	\$4,323.31 \$8,981.31	NO BID	NO BID	\$5,509.62/ \$9,423.62	\$ 4,327.56/ \$ 8,569.56	\$ 4,192.63/ \$ 8,522.63
3 EA 300KVA, 208/120V	\$18,423.75/ <u>\$39,681.75</u>	\$17,936.00/ \$41,024.00	NO BID	NO BID	\$30,097.91/ \$44,485.91	\$18,882.75/ \$40,248.75	\$17,658.75/ \$40,698.75

FOOTNOTES: * BIDS RECEIVED ARE TOTAL BID PRICES FOR EACH SIZE, TAXES INCLUDED, DELIVERED

- (1) CENTRAL MOLONEY DISQUALIFIED DUE TO LACK OF SERVICE FACILITIES WITHIN 200 MILES OF LODI; HEIGHT FOR ITEM 2 EXCEEDS SPECIFIED LIMIT OF 28"
- (2) WESTERN STATES' PROPOSAL FAILED TO MEET SPECIFICATIONS IN THAT APPLIED VOLTAGE TESTS ARE NOT PERFORMED ON GRD. WYE UNITS; TRANSFORMER HEIGHTS ARE NOT INDICATED.
- (3) GENERAL ELECTRIC'S PROPOSAL CONTAINED LOSS EVALUATION CLAUSES WHICH DIFFERED FROM SPECIFICATIONS; DRAWINGS SUBMITTED INDICATE ONLY ONE PARKING STAND ON SINGLE-PHASE UNITS VS. TWO AS SPECIFIED; BAYONET FUSES DO NOT MATCH SPECIFICATIONS; TRANSFORMERS "MAY NOT IN ALL CASES MEET CUSTOMER REQUIREMENTS ON MAXIMUM HEIGHT".
- (4) PAUWELS' PROPOSAL INDICATES TRANSFORMER HEIGHTS ARE "NOT BINDING".